

Holland Massachusetts

Board of Health

Meeting Date: Tuesday, September 08, 2009

Members in Attendance: David Kowalski, Ray Korney, Jeff Wojtowicz

Meeting Opened: 7:00PM

Meeting Closed: 7:45PM

Board of Health Meeting for Date:9/8/2009 Meeting called to order Time:7:10PM

Members in Attendance: David Kowalski, Ray Korney, Jeff Wojtowicz

Motioned 7:10 Dave motioned Jeff Seconded

Minutes of Previous Meeting (8/25/2009) were read and accepted as written.

BOH received a complaint about a house on Mountain road. Tight tank is overflowing. Ray went there Labor Day and advised homeowner to pump tank as soon as possible.

Larry & June Burleigh - 16 Craig Road - 72 Attawanhood Trail Eamston CT 06231
Will be rebuilding house.

Jean Curtis - Sturbridge Road - Well Permit and Septic Approval. Get with Arthur about Jeans plan.

***** PUBLIC HEARING *****

Hearing Called: 9/8/2009 7:30PM

Now comes Mark Farrell for Alan Burrill of 26 Stony Hill Road , Holland MA 01521 for the purpose of Tight tank plan approval.

Requires 4 variances

Abutters in Attendance:0

Green Cards Presented:2

Certified Letters Returned:0

- Variance to 310 CMR 15.211 (1) The proposed SAS does not meet the required setback from a well 50ft required 45ft provided (owner's well).
- Variance to 310 CMR 15.211 (1) The proposed SAS does not meet the required setback from a property line 10ft required 1ft provided (private road).
- Variance to 310 CMR 15.211 (1) The proposed Septic Pump Chamber etc. does not meet the required setback from a property line 10ft required 2ft provided.

Holland Massachusetts

Board of Health

Meeting Date: Tuesday, September 08, 2009

Members in Attendance: David Kowalski, Ray Korney, Jeff Wojtowicz

Meeting Opened: 7:00PM

Meeting Closed: 7:45PM

- Variance to 310 CMR 15.211 (1) The proposed Septic Pump Chamber etc. does not meet the required setback from a foundation 10ft required 5ft provided.

Dave Motioned

Passed unanimously.

Dave Motioned to Adjourn meeting Ray / Jeff seconded.

Meeting Adjourned:7:45PM