

# *Holland Massachusetts*

# *Board of Health*

**Meeting Date:** June 6, 2006  
**Members in attendance:** Heather Blakeley, Tom Baltazar, Dave Kowalski  
**Meeting Opened:** 7:20 PM  
**Meeting Closed:** 8:35PM

Dave motioned, Heather seconded - Meeting called to order 7:20 PM

Approved minutes for 03/21/06 as written.

Appointments - Ray Korne and all currently appointed BOH members will re-appoint all those currently appointed by the BOH.

\*\*\*\*\*Public Hearing Marie Quattrocelli – 11 Ardmore Road \*\*\*\*\*

Marie Quattrocelli -11 Ardmore Road - Marie Quattrocelli  
Abutters Robert or Robin Marin 9 Ardmore Road not in attendance

- Variance to 310 CMR 15 SAS does not meet required setback from a well 100 ft required 86 ft provided (nf Marin well)

Septic Construction Permit 060606-1 issued.

Water Tests OK

Ray Korne will fill in for Sarto 6/24 and 6/25

Joan Dusco - For HBOH Emergency Alert Contact

(ECS) Environmental Compliance Service Report for Jan 2006 Landfill Monitoring

Mark Koomey - 23 Lee Ave - Title V Septic Passed - Well 60 feet passed, neighbors well 85 feet failed for nitrates. BOH will notify Mr. Hoit about nitrates in well. BOH will issue Certificate of Compliance based on fact that neighbors septic is only 50 feet from his well and may be contaminating his well.

Heather Motioned to approve Tom seconded approved unanimously.

Bill Krukowski Lot 1 Mashapaug Rd - Septic Design - dropped off septic plan for approval.

Daniel Meara - 5 Oak Ridge Drive - Septic Plan Approval - Public Hearing must be held. scheduled for 6/20/06 7:30 PM

John Bercume - Monette Landscape and Construction came in took and passed the installers test. 060606-2 issued.

Rebecca Perri - 10 Old Country Road - Pink sheet must be signed. 2006-1085  
Heather signed - construction rebuild of 3 bedroom house.

Peter Schartner - 44 Over the Top -Pink sheet 2006-1064 signed – Septic Construction Permit 060606-3 issued. - Tight Tank approved by DEP.

Heather motioned, Dave seconded – Meeting adjourned 8:35PM