

Holland Massachusetts

Board of Health

Meeting Date: November 4, 2003
Members in attendance: Sally Blais, John Robbins, Dave Kowalski, Tom Baltazar
Meeting Opened: 7:30PM
Meeting Closed: 9:30PM

John motioned, Dave seconded – Meeting Opened 7:30PM

Minutes from 10/21/2003 meet read and accepted as written.

Donnelly – 24 East Brimfield Road R20-B 1.14 System Installed 09/03/2002 came in for copy of BOH records.

Charles Smith – 18 Allen Hill Road – Septic plan approval and well permit. Well permit 110403-1 issued.

Paul Gillis – Senior Center Building Committee – came in with questions about well and septic. Sally discussed requirements for well and made several suggestions.

Anthony Ianniccheri – East Brimfield Road Holland – Came in to have procedure sheet signed. John signed procedure sheet.

*****Continuance of Public Hearing ***** for Tammy & Edward Zawistowski*****
Steve Bressette (Jalbert Engineering) for Tammy & Edward Zawistowski - 17 Island Road

Last meeting three variances were approved regarding the required set back from neighboring wells. Mr. LaPlante called Sally and is still opposed to the system. BOH said his opposition would be noted in the minutes.

Two more variance are required

- Variance to 310 CMR-15.211 proposed SAS does not meet required setback from a property line namely the street 10 feet required 6 feet provided.
- Variance to 310 CMR-15.211 ground water separation for a 2 minute perk, 5 ft required 4ft provided.

Dave made a motion that variances be approved, John seconded motion.

The two variances were approved unanimously.

Dave motioned, John seconded - Meeting adjourned 9:30 PM