

Holland Massachusetts

Board of Health

Meeting Date: Tuesday, November 23, 2010

Members in Attendance: David Kowalski, Bob Dymon, Jeff Wojtowicz

Meeting Opened: 7:30PM

Meeting Closed: 8:00PM

Board of Health Meeting for Date:11/23/2010 Meeting called to order Time:7:30PM

Members in Attendance: David Kowalski, Bob Dymon, Jeff Wojtowicz

Motioned 7:30□ Dave Motioned Jeff Seconded. Meeting opened.

Minutes of Previous Meeting (11/9/2010) were read and accepted as written.

***** Public Hearing *****

Stever Bressette - Jalbert Engineering came in for plan approval for Scott & Diane Balderelli of 6 Pleasant Road.

Two variances required - abutters need not be in attendance.

- Variance to CMR15 Ground water separation from 4ft required 3 ft provided code allows down to 2 ft separation

- Variance to CMR15 Owners well does not meet required setback from a leach field 100ft required 74ft provided.

Board grants variances. Plan approved for production. Letter prepared for Balderelli's

Raymond LaBonte - 137 Mashapaug Road - House is to be demolished and septic system will be reused. Existing structure is a two bedroom structure and septic system is designed for a two bedroom house. Dave signed pink sheet 2008-1384

Dave Motioned to Adjourn meeting Bob seconded.

Meeting Adjourned:8:00PM