

Holland Massachusetts

Board of Health

Meeting Date: Tuesday, December 14, 2010

Members in Attendance: David Kowalski, Bob Dymon, Jeff Wojtowicz

Meeting Opened: 7:15PM

Meeting Closed: 7:45PM

Board of Health Meeting for Date:12/14/2010 Meeting called to order Time:7:15PM

Members in Attendance: David Kowalski, Bob Dymon, Jeff Wojtowicz

Motioned 7:15□ Dave Motioned Jeff Seconded. Meeting opened.

Minutes of Previous Meeting (11/23/2010) were read and accepted as written.

***** Public Hearing *****

Mark Farrell - Public Hearing - Paul Hammel - 24 Old Acres - Meeting called no abutters in attendance.

6 Variances Required.

- Variance to CMR15 well does not meet required setback from SAS 100 ft required 55ft provided (n/f Erickson)
- Variance to CMR15 well does not meet required setback from SAS 100 ft required 55ft (n/f Harrington)
- Variance to CMR15 Leach Field 5 ft from property line 10 ft required 5 ft provided
- Variance to CMR15 Pump Chamber is 5 ft from property line 10 ft required 5 ft provided
- Variance to CMR15 leach field is 6 ft from foundation 10 ft required 6 ft provided
- Variance to CMR15 18% reduction in size of leach field.
- Variances approved

Board of Health approved ECS monitoring of landfill on E. Brimfield Road Holland \$5850.00

Dave Motioned to Adjourn meeting Bob/Jeff seconded.
Meeting Adjourned:7:45PM