

Holland Massachusetts

Board of Health

Meeting Date: October 28, 2008
Members in attendance: John Jacobi, Dave Kowalski
Meeting Opened: 7:25PM
Meeting Closed: 8:30PM

Dave Motioned, John seconded - Meeting called to order 7:25PM

Minutes from previous meeting read and approved as written.

Mr. Robert Patnode – 44 Mashapaug Road – came in for septic plan approval.

Non standard septic system.

- Variance to 310 CMR 15.212 SAS ground water separation 5' required 4' provided, code allows down to 2'.

Variance approved unanimously.

John Motioned – Approve plan and variance – contingent upon O&M (Operation and Maintenance Agreement) being presented within 30 days of this meeting.

John signed construction permit and pink Sheet 2008-1307

Emergency well permit issued Charles Breen – 75 Sandy Beach Road 102708-1 contingent upon acceptable drawing. Drawing produced by Charlton well was deemed to be satisfactory.

Michael Santos Lot 1 Butterworth Road – Septic plan review and acceptance.

John has no objections Dave seconded plan approved. John signed pink sheet 2008-1311. Mr Santos also came in on October 29th for a well permit. Well more than 100 ft from septic system, new construction. Permit 102908-1 issued.

Mr. Wheeler- 8 Lee Ave – Tight Tank – John signed construction permit for tight tank.

Jerold Joliceur - 21 Island Road - Tight Tank Dave Pourier installing – John signed construction permit for tight tank

Public hearing to be held November 10th 2008 for Kowalski – 344 Mashapaug Road. Mark Ferrell, John Jacobi and Dave Kowalski have worked out a septic plan that should be acceptable to all concerned.

Meetings for November will be November 10th and November 25th
Dave will notify Executive Secretary and Town Clerk for postings.

Dave motioned, John seconded – Meeting Adjourned 8:30PM