

# *Holland Massachusetts*

# *Board of Health*

**Meeting Date:** October 9, 2007  
**Members in attendance:** Heather Blakely, Dave Kowalski, Tom Baltazar  
**Meeting Opened:** 7:25PM  
**Meeting Closed:** 8:50PM

Dave made motion to call meeting to order, Heather seconded. Meeting called to order 7:25 PM.

Heather motioned to pay bills in the amount of \$7,960.88 dollars / Dave seconded  
Maintenance Services invoices 1,575 and 1,350.  
Arthur Quinn 750.00  
Vincent McCaughey 400.00  
Staples \$149.88  
Arthur Quinn 750.00  
ECS 2985.90

Stuart Curboy – Looking for perk test information

Jessie K Cooley – Well permit 092607-3  
G Victoria Wattendorf – Well Permit 092607-2  
Douglas D. Leasor – Well Permit 092607-1

Heather makes motion to approve well permit for 87 Brimfield Road – Requiring and engineered plan with certified asbuilt showing location of well and septic system in reference to the house. Well should be greater than 100 ft from septic system if less a variance may be issued down to fifty feet. 100907-01 emergency permit issued.

Dave will go to 79 Sturbridge Rd and 81 Sturbridge Rd to determine that leach field is 100ft from proposed well. Dave must determine that well will be at least 50 ft from leach field. Jean Curtis 508 248-7063.

Michael Morin - 231 Brimfield Road – Needs variance owners well is 73 ft from SAS code is 100 ft. Pink sheet 2007-1236 Heather Signed – Stamped approved copy of plan. Ron Cox

Jerry Doyle 13 Masaconic Trail – Pink sheet – Will tear down and rebuild Pink sheet 2 bedroom tight tank  
2007-1231 Heather signed pink sheet.

Mark Ferrel – 59 Island Road Roger Perry – variance well to tight tank 35 ft 50 ft required. Heather motioned Dave and Tom seconded all in favor – variance granted.

Open public hearing 24 Halfway Lane – approve variance from proposed well to neighbors leach field 100ft required 60ft provided.

Dave motioned Tom seconded meeting adjourned 8:50PM