

Holland Massachusetts

Board of Health

Meeting Date: April 4, 2006
Members in attendance: Heather Blakeley, Dave Kowalski
Meeting Opened: 7:20PM
Meeting Closed: 8:55PM

Dave motioned Heather Seconded -Meeting opened 7:20PM

David Dwyer - 93 Wales Road Holland 17 - A - 10.2.1 Septic Construction Permit and Well Permit requested on new construction. Plan reviewed by Arthur and BOH members - New Construction meets required setbacks etc. Construction permit 040406-1 issued Well Permit 040406-2 issued. pink sheet 2005-1020 signed by Heather Well permit check # 115

Gene Lord - 20 Lake Shore Drive - wanted Certificate of Title V - Comp signed. We cant because asbuilt not submitted. Heather will sign tomorrow if Mr. Lord brings as built tomorrow.

David Kenniston (Ron) - 32 Craig Rd. Looking for septic construction permit and well permit. Plan reviewed by Arthur requires 3 variances.

- Variance to 310 CMR 15 SAS does not meet required setback from a well, 100 ft required 74 ft provided (nf Owner)
- Variance to 310 CMR 15 Septic Tank does not meet required setback from a property line 10 ft required 6 ft provided.
- Variance to 310 CMR 15 SAS does not meet required setback from a property line 10 ft required 5ft provided.

Variances passed unanimously.

Septic Construction Permit 040406-3 issued.
Well Permit 040406-4 issued.

John Day for Dan Meara - 5 Oak Ridge Drive - Septic Construction permit. Need perk ASAP - Tim MacGinnis 413 527 5291

Peter Schartner - 44 Over the Top - received letter from DEP. Need letter from BOH saying plan acceptable to BOH. Heather will send letter to DEP and fax to Mr Schartner 508 764-166.

David Sears - came in to ask about variance on 10 Julia Anna drive for potential buyer.

Dave motioned, Heather seconded – Meeting adjourned 8:55PM