## Holland Massachusetts

## Board of Health

Meeting Date: Tuesday, August 09, 2016 Members in Attendance: David Kowalski, Erin Even

Meeting Opened: 7:00 PM Meeting Closed: 7:40 PM

Board of Health Meeting for Date:8/9/2016 Meeting called to order Time:7:00 PM

Members in Attendance: Dave Kowalski, Erin Even

Minutes of Previous Meeting (7/26/2016) were read and accepted as written.

David Joy 2 Stony Hill Road Leach Field upgrade

## 2 Variances required

- Variance to 310 CMR 15.211 (1) The proposed SAS does not meet the required setback from a well 100ft required 70ft provided (nf Lach well).
- Variance to 310 CMR 15.211 (1) The proposed SAS does not meet the required setback from a property line 10ft required 6ft provided (nf Cawley property line).

Unanimously approved construction permit 08-09-16-1 issued

Dave Motioned to Adjourn meeting Erin seconded.

Meeting Adjourned:7:40PM