

# *Holland Massachusetts*

# *Board of Health*

**Meeting Date:** July 6, 2004  
**Members in attendance:** Heather Blakeley, David Kowalski, Tom Baltazar  
**Meeting Opened:** 7:00PM  
**Meeting Closed:** 8:30PM

Dave motioned, Heather seconded – Meeting Opened 7:00PM

Brian Johnson – 61 Stafford Road – Septic plan approval. Septic Construction permit 070604-1 issued.

Completion report from Charlton well for well which was installed in 1996. Water Test presented and pink sheet signed.

\*\*\*\*\* Public Hearing Nick Sotar – 29 Williams Road \*\*\*\*\*  
One variance required

Frederick & Kathleen Elmy – 32 Williams Road abutters in attendance. Expressed concern that new septic system would contaminate their well. BOH explained recourses available to Elmy's.

- Variance to 310 CMR 15.212 (1) The proposed SAS does not meet the required setback from a well 100ft required 57.8ft provided (nf Elmy well).

Dave made motion, Heather seconded motion variance passed with the following restrictions. Property shall be surveyed by registered surveyor prior to construction. Septic construction Permit 070604-2 issued.

Robert Burlingame – 49 Leno Road – Well Permit 070604-3 issued. BOH will check to see well is 100+ feet from SAS.

Elizabeth A Purdy 56 S Cottage Road – Well permit 070604-4 issued.

Dave motioned, Heather seconded - Meeting adjourned 8:30 PM