

## ***Holland Massachusetts***

## ***Board of Health***

**Meeting Date:** Tuesday, June 10, 2014

**Members in Attendance:** David Kowalski, Dana Manning, Ken Ference

**Meeting Opened:** 7:15

**Meeting Closed:** 8:27:17 PM

Board of Health Meeting for Date:6/10/2014 Meeting called to order Time:7:15

Members in Attendance: David Kowalski, Dana Manning, Ken Ference

Minutes of Previous Meeting (5/13/2014) were read and accepted as written.

Bud Webb Lot 8 #19 Butterwood Ext Installer Permit 061014-1 Issued

Jean Charlton Well - Jean Sullivan Came in for emergency well permit 1 Old E Brimfield Road. Permit 061014-2 Issued

\*\*\*\*\* PUBLIC HEARING \*\*\*\*\*

Hearing Called: 6/10/2014 7:50:12 PM

Mark Ferrell for Rich Heineman - 27 Candlewood Dr.

Now comes Mark Ferrell and/or Rich Heineman of 27 Candlewood Dr.,  
Holland MA 01521 for the purpose of Septic system repair

Abutters in Attendance: None

Green Cards Presented: 2

Certified Letters Returned: 0

- Variance to 310 CMR 15.211 (1) The proposed SAS does not meet the required setback from a well 100ft required 65ft provided (nf Wyszomirski well).
- Variance to 310 CMR 15.211 (1) The proposed SAS does not meet the required setback from a property line 10ft required 6ft provided (nf Dilizia property line).
- Variance to 310 CMR 15.211 (1) The proposed SAS does not meet the required setback from a foundation 10ft required 6ft provided (nf Heineman foundation).
- Variance to 310 CMR 15.211 (1) The proposed Septic Tank/Pump Chamber etc.

## ***Holland Massachusetts***

## ***Board of Health***

**Meeting Date:** Tuesday, June 10, 2014

**Members in Attendance:** David Kowalski, Dana Manning, Ken Ference

**Meeting Opened:** 7:15

**Meeting Closed:** 8:27:17 PM

does not meet the required setback from a well 50ft required 40ft provided (nf Wyszomirski well).

Dave Motioned unanimously approved

Now comes Mark Ferrell and/or Mr. Mark LaMontagne of 25 Old Country Rd, Holland MA 01521 for the purpose obtaining a well permit 061014-3 issued

Mark attests new well more than 100 ft from any SAS. Tanks will be more than 65 ft from well.

Dave motioned Ken Seconded unanimously approved.

Lauren Barker 17 Lakeridge Drive. Came in to have the pink sheet Dave signed yellow sheet - construction approved with existing septic system. LeBlanc did Title V inspection and water test - no problems.

Matthew Stewart Lot 1.8 Vinton came in for copy of perk test (board has not info).

Dave Motioned to Adjourn meeting Bob seconded.

Meeting Adjourned:8:32:17 PM