

Holland Massachusetts

Board of Health

Meeting Date: November 2, 2004
Members in attendance: Heather Blakeley, Tom Baltazar, Dave Kowalski
Meeting Opened: 7:30PM
Meeting Closed: 8:00PM

Heather motioned, Dave seconded - Meeting Opened 7:30PM

Dave read minutes of previous meeting. Heather motioned, Tom seconded, minutes accepted as written.

Sarto Caron - Brush dump 11 hours for period 10/30 and 10/31.

Fred Trifone - 119 Stafford Road - Certificate of Title V Compliance. Arthur must sign inspection. Heather will have it signed tomorrow.

Tom Baltazar - Had two perk tests performed on his property at 12 Sandy Beach Road and 16 Stony Hill Road. Perk plan and inspection. paid for.

Brenda McGillvary - Lot 3 Shawnee Road R36-D 3,4,5,8,9 Came in to have pink sheet signed. Septic Construction permit issued 051804-7.

197 Mashapaug Road - Barry Cohen - Title V performed well within 50 ft of septic system. Installed new well 9/18 Title V can be changed to passed based on installation of new well.

7 Hamilton - Beverly Connors - Title V performed well within 100 ft of leach field - Owners well water tested OK Title V changed to passed based on water test.

8 Forrest Court - Michelle D DeAngelis - Well 50 ft from septic water test passed. Title V changed to passed.

24 Graig Road - Jenet Trembaly and Robert Trembaly 2 wells within 50 feet of septic system. Need to send letter indicating wells or leach field have to be moved.

Elliot Burlingame & Sons 91 # 5 School House Road Charlton MA 01507.
110304-1 Septic installers permit issued. 508 248 5076

Meeting adjourned 8:00 pm

Letters that must be written:

3 Lake Dr - Barbara Fitzsimons - needs letter for failed system - needs to upgrade within 2 years.

25 Sandy Beach Rd - John Panula – Septic failed because of roots and well less than 50 feet from SAS.

57 Sturbridge Road - Paul Pikora - Failed - pit full to cover

44 Over The Top - Clifford Leonard - Cesspool full and well 47ft from SAS

17 leisure Drive - John O'Connor - failed metal tank and field clogged.

47 Lake Drive - Walter Damen - Dan Bugnacki leach field overloaded well 28 ft from field.

24 Half Way Lane – Victoria Healy - need to check if well was installed.