

Holland Massachusetts

Board of Health

Meeting Date: Tuesday, July 12, 2011

Members in Attendance: David Kowalski, Bob Dymon, Jeff Wojtowicz

Meeting Opened: 7:20PM

Meeting Closed: 8:15PM

Variance approved unanimously - Septic Construction permit 071211-1 issued.

***** Public Hearing *****

Mary Vandenberg - 27 Hamilton Drive

No abutters in attendance.

6 Variances required

Variances approved unanimously - Septic Construction permit 071211-2 issued.

***** Public Hearing *****

Vincent Donato - 91 Maybrook Road

No abutters in attendance

3 Variances required

Variances approved unanimously - Septic Construction permit 071211-3 issued.

John Shermann 137 East Brimfield Road Septic Construction 071211-4 issued new construction no variances required.

Dave Motioned to Adjourn meeting Bob/Jeff seconded.

Meeting Adjourned:8:15PM

Holland Massachusetts

Board of Health

Meeting Date: Tuesday, July 12, 2011

Members in Attendance: David Kowalski, Bob Dymon, Jeff Wojtowicz

Meeting Opened: 7:20PM

Meeting Closed: 8:15PM

Board of Health Meeting for Date:7/12/2011 Meeting called to order Time:7:20PM

Members in Attendance: David Kowalski, Bob Dymon, Jeff Wojtowicz

Minutes of Previous Meeting (6/28/2011) were read and accepted as written.

***** Public Hearing *****

Public Hearing 39 Craig Rd - Woodward

No abutters in attendance

Green Cards and Letters Presented

8 Variances

- Variance to 310 CMR 15.211 Proposed SAS does not meet required setback from a well 100 ft required 55 ft provided (n/f eyles)
- Variance to 310 CMR 15.211 Proposed SAS does not meet required setback from a well 100 ft required 55 ft provided (n/f ricard)
- Variance to 310 CMR 15.211 Proposed SAS does not meet required setback from a well 100 ft required 85 ft provided (n/f owner)
- Variance to 310 CMR 15.211 Proposed SAS does not meet required setback from a property line 10 ft required 7 ft provided (n/f laing)
- Variance to 310 CMR 15.211 Proposed well does not meet required setback from a leach field 100 ft required 65ft provided (n/f eyles)
- Variance to 310 CMR 15.211 Proposed well does not meet required setback from a leach field 100 ft required 70ft provided (n/f jovan)
- Variance to 310 CMR 15.211 Proposed septic tank does not meet required setback from a well 50ft required 40ft provided (n/f owner)
- Variance to 310 CMR 15.211 Proposed SAS does not meet required setback from a foundation 20 ft required 10 ft provided (n/f owner)