

## ***Holland Massachusetts***

## ***Board of Health***

**Meeting Date:** Tuesday, November 08, 2011

**Members in Attendance:** David Kowalski, Bob Dymon, Jeff Wojtowicz

**Meeting Opened:** 7:15PM

**Meeting Closed:** 8:00PM

Board of Health Meeting for Date:11/8/2011 Meeting called to order Time:7:15PM

Members in Attendance: David Kowalski, Bob Dymon, Jeff Wojtowicz

Minutes of Previous Meeting (10/25/2011) were read and accepted as written.

WebFirst 4 Lakeridge Drive Holland - Well permit # 110811-1 issued

McCoo came in for Title V letter of compliance signature.

\*\*\*\*\* Public Hearing \*\*\*\*\*

Edward Cusson 10 Blodgett Road Holland - Septic Repair

Two variance required.

Abutters in attendance Mr. Remijan

Green cards presented.

- Variance to 310 CMR 15.211 (1) The proposed says does not meet required setback from a well 100 ft required 65 ft provided (N/F Remijan)

- Variance to 310 CMR 15.211 (1) The proposed sas does not meet required setback from a well 100 ft required 65 ft provided (n/f Owner)

Variances unanimously approved.

Septic construction PERMIT 110811-2 issued

\*\*\*\*\* Public Hearing \*\*\*\*\*

Public Hearing - 12 Lakeshore Drive

McKenna 12 Lakeshore Drive

No Abutters in attendance

Two variances required

## ***Holland Massachusetts***

## ***Board of Health***

**Meeting Date:** Tuesday, November 08, 2011

**Members in Attendance:** David Kowalski, Bob Dymon, Jeff Wojtowicz

**Meeting Opened:** 7:15PM

**Meeting Closed:** 8:00PM

Green cards presented.

- Variance to 310 CMR 15.211 (1) The proposed says does not meet required setback from a well 100 ft required 88 ft provided (N/F Weeks)
- Variance to 310 CMR 15.211 (1) The proposed sas does not meet required setback from a well 100 ft required 85 ft provided (n/f owner)

Variances unanimously approved.

Septic construction PERMIT 110811-3 issued.

Dave Motioned to Adjourn meeting Bob seconded.

Meeting Adjourned:8:00PM