



Microbac Laboratories, Inc. - Dayville

## CERTIFICATE OF ANALYSIS

D1F2557

### Holland Board of Health

Beaches Program  
27 Sturbridge Road  
Holland, MA 01521

### Project Name: Holland Pond

Project / PO Number: N/A  
Received: 06/28/2021  
Reported: 06/30/2021

### Analytical Testing Parameters

Client Sample ID:	Holland Pond	Collected By:	Tom Baltazar
Sample Matrix:	Recreational Water	Collection Date:	06/28/2021 11:33
Lab Sample ID:	D1F2557-01		

Microbiology	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: SM 9223 B (Colilert Quanti-Tray)-2004								
Escherichia coli	5.2	235	1	MPN/100mL		06/28/21 1625	06/29/21 1930	DCH

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

### Definitions

**MPN/100mL** Most Probable Number per 100 Milliliters  
**RL:** Reporting Limit

### Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville  
M-CT008

Massachusetts Department of Environmental Protection

### Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.**

### Reviewed and Approved By:

Melisa L. Montgomery  
Quality Assurance Officer  
Reported: 06/30/2021 15:19

Microbac Laboratories, Inc.

61 Louisa Viens Drive | Dayville, CT 06241 | 860.774.6814 p | [www.microbac.com](http://www.microbac.com)

Page 1 of 3



Microbac Labo  
61 Louisa Vi  
Dayville, C

CUSTOMER: TOWN OF HOLLAND

ADDRESS:

DELIVERY: TOM BALTAZAR

E-MAIL: TAZAR1@HOTMAIL.COM

PHONE: 503-245-2525 FAX:

### Sample Identification

Date Collected

Sample Matrix

Composite

Grab

Bottle Qty

④ HOLLAND POND

06/28/21 11:33



D 1 F 2 5 5 7

Holland Board of Health

BILL TO: TOWN OF HOLLAND BOH

ADDRESS: 27 STURBRIDGE ROAD

HOLLAND, MA 01521

ATTN: DAVE KAWALSKI

PHONE: 413-245-7108 x112

E-MAIL: BOH@TOWN OF HOLLAND.CX MAIL.COM

PURCHASE ORDER #:

Project Manager:

Project:

Location:

Project Mgr:

E-MAIL:

PHONE:

FAX:

NON-PRES  
HCL  
HNO<sub>3</sub>  
H<sub>2</sub>SO<sub>4</sub>  
OTHER

TURNAROUND TIME REQUESTED (select):

Standard

RUSH

Day

Circle Delivery Method:

E-MAIL

HARD COPY

OTHER

CONDITIONS UPON RECEIPT: (CHECK ONE)

COOLED

☐

AMBIENT

☐

Upon receipt at lab

# Beach Sampling Field Data

Revised 2018

Town/City: HOLLAND  
Date Collected: 06/28/21  
Collected by: TOM BALTAZAR

Time Delivered to Lab: 12:25  
Delivered by: TOM BALTAZAR  
Relinquished to: MICROBAC LAB

ID #	Sample Location if beach has multiple samples, note location.	Marine or Fresh	Sample Time	Water Clarity:			Water Temp (°F)	Wave Intensity:			Days Since Rain 10" or within 24 hrs	Potential Pollution Sources - if none, check "none"							
				Clear	Partly murky	Murky		Calm	Normal	Rough		# People in Water	# Birds	# Dogs	Algae	Trash	Animal/ Human waste	Wrack	None
	Sandy Beach	M	9:30 am	C	P	(M)	68	(C)	N	R	0	0	5	0					
	Sunset Pines	F	6:35 am	C	(P)	M	72	C	(N)	R	7	7	0	0		✓			
	Excellent Point	F	1:00 am	(C)	P	M	70	C	N	(R)	2							✓	
(4)	HOLLAND POND	F	11:33	(C)	P	M	82	C	(N)	R	3	16	0	0				✓	
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									
				C	P	M		C	N	R									

Cloud Cover: Clear Partly Cloudy Cloudy/Overcast

Comments:

A copy of this form must be included with the samples when they are submitted to the lab.