



Microbac Laboratories, Inc. - Dayville  
**CERTIFICATE OF ANALYSIS**

D1F0086

Holland Board of Health

Project Name: Collette Drive Beach

Beaches Program  
 27 Sturbridge Road  
 Holland, MA 01521

Project / PO Number: N/A  
 Received: 06/01/2021  
 Reported: 06/14/2021

**Analytical Testing Parameters**

Client Sample ID:	Collette Drive Beach	Collected By:	Tom Baltazar
Sample Matrix:	Recreational Water	Collection Date:	06/01/2021 10:28
Lab Sample ID:	D1F0086-01		

Microbiology	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: SM 9223 B (Collert)-1997</b>								
Escherichia coli	17.3	235	1	MPN/100mL		06/01/21 1547	06/02/21 1832	KPP

*Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

**Definitions**

MPN/100mL Most Probable Number per 100 Milliliters  
 RL: Reporting Limit

**Project Requested Certification(s)**

Microbac Laboratories, Inc. - Dayville  
 M-CT008

Massachusetts Department of Environmental Protection

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Melisa L. Montgomery  
 Quality Assurance Officer  
 Reported: 06/14/2021 12:41

Microbac Laboratories, Inc.